



City of Menomonie

*800 Wilson Avenue
Menomonie, WI 54751
715 232 2369*

November 4, 2019

Public Notice

On November 4, 2019, an aeration tank at the City of Menomonie Wastewater Treatment was found leaking onto the front lawn of the treatment plant. City staff responded and the tank was immediately taken off-line and pumped down. The area impacted is approximately 1,000 square feet and the volume is estimated at 500 gallons. All of the leakage remained on the lawn and did not make its way to any storm drains or surface waters. City crews vacuumed up the standing water and residual solids and will inspect and repair the tank. The Wisconsin Department of Natural Resources has been notified. Pursuant to the requirement of NR 210, this public notice is being posted regarding this event.